



THE TECHNICAL UNIVERSITY OF KENYA

Haile Selassie Avenue, P. O. Box 52428, Nairobi, 00200, Tel: +254 (020) 3343672, 2219929, 0732388765,

E-mail: vc@tukenya.ac.ke, Website: www.tukenya.ac.ke

ADDENDUM FOR TENDER NO: TUK/T/01/2022/2023 FOR THE PROPOSED CONSTRUCTION OF BLOCK T AND I AT THE TECHNICAL UNIVERSITY OF KENYA.

The following alteration and clarifications shall form part of Tender no: TUK/T/01/2022/2023 and subsides the details of the previous notice following pre-bid meetings and concerns thereof.

S/no.	Description	Addendum /Clarification
1.	Tender submission validity period	The Tender submission validity period has been extended from 3 rd May 2022 to 10 th May 2022
2.	Tender Security	Section II – Instructions to tenderers: Amend Clause 3.8 to read - The format of the Tender Security should be in accordance with the form of Tender Security included in Section VI - Standard forms or any other form acceptable to Technical University of Kenya (TU-K). <i>Tender Security shall be valid for 150 days from the date of submission and not Tender Security shall be valid for 30 days beyond the validity of the tender.</i>
3.	Missing page 6 (six)	There is no missing page 1/6 of the particular preliminaries section, save for numbering order.
4.	Sub- Contractors NCA requirements	Electrical installations, fire alarm and Detection Systems installations; Sub - contractors must be registered in NCA 1 , whereas the following electrical associated installations shall be registered in NCA 2 & above all as indicated in the mandatory requirement criteria; a. Lift installations b. Generator installations c. Security installations d. Audio Visual Installations e. Communication Services installations f. UPS installations – NCA 3 and above

ADDENDUM FOR TENDER NO: TUK/T/01/2022/2023- PROPOSED CONSTRUCTION OF BLOCK T AND I OF THE TECHNICAL UNIVERSITY OF KENYA

5.	Generator Installations	<p>Generator Installations Page L1-3/8, Item 23 – The description says '(Note: generator to be supplied by 4 No. 4C 240mm² PVC/SWA/PVC cable run in parallel therefore provide quote for 4No. 4C 240mm² PVC/SWA/PVC for 150m).'</p> <p>This shall remain as it is.</p>
6.	Lift Installations	<p>Lift Installations Page L1-3/8, Item 23 – The description says 'Supply 1000 kg (13 persons) machine-room-less passenger lifts with durable flat polyurethane coated high-tensile grade steel belts'. Query was to change from belt to ropes. The description shall remain as it is. Traditional steel ropes shall not be allowed.</p>
7.	Audited books of Accounts	<p>Provide the audited accounts for the last four (4) years of your entity's financial calendar</p>